



BCRA testing as stated in Dm 236 is an instrumental survey that provides the measurement of dynamic friction (μ) specifying at point 8.2.2 that "Anti-slip flooring is flooring made of materials whose coefficient of friction, measured according to the method of the British Ceramic Research Association. (B.C.R.A.)

Test results:

Note:

Requirement requested by D.M. (Decree) of June 14, 1989,
No. 236 Article 8.2.2:

- for sliding element in leather on dry flooring, $\mu > 0.40$
- for sliding element in rubber on wet flooring, $\mu > 0.40$

